Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: 32 (0)2 264 03 60
Fax: 32 (0)2 268 89 58
http://www.apragaz.com
info@apragaz.com

BELAC Cert n° 084-PROD

APRAGAZ

Member of CEOC INTERNATIONAL

EC TYPE - EXAMINATION

In accordance with module B of Directive 2014/90/EU on Marine Equipment

Certificate N°
18/GR/4431-0-REV 0

Manufacturer	Name	**ANAF FIRE PROTECTION S.P.A.**
	Address	**Via del Commercio 4** **IT - 27020 Torre d'Isola (Pavia)** **ITALY**
Brand Applicant	Name	**LALIZAS HELLAS**
	Address	**3 Gounari, 18531 Piraeus** **GREECE**

Concerned Equipment: Portable Fire Extinguishers (Powder Stored Pressure)

Type: Lalizas 70444X (X is substituted by a number depending available languages on the label)

Technical documents : Technical design ref. 33.250B.F000.00/cert.ref.03/IT/531

Capacities: 2 kg

Fire Rating : 13A 89B C

Set pressure: max. 16,78 bar (+60°C)

Test pressure: 24 bar

Service temperature range: min. -30°C / max. +60°C

The manufacturer is allowed to affix the marine CE mark (followed by the n° and the year of manufacturing) to approved equipment in the conditions described in article 10 of the Directive , only if the requirements stated in module D are fully complied with.

The approval is valid until 16/09/2022

APRAGAZ, acting within the scope of its notification for the above mentioned Directive, certifies that the types of equipment defined here above are conform to the requirements of the EN 3.7 in force and to the Marine Equipment Directive 2014/90/EU (as amended), on base of the documentation and samples supplied for review and approbation.

Date : **05/11/2018** Name : **Ch. Leplat** Position **General Manager**

Notified body identification number : **0029**

Signature

Notified body stamp :

APRAGAZ
Belgium
Inspecting Authority

Notified body reference : **P17676/000**