



Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: 32 (0)2 264 03 60
Fax: 32 (0)2 268 89 58
http://www.apragaz.com
info@apragaz.com



EC TYPE - EXAMINATION		Certificate N° 18/GR/4428-0-REV 0
In accordance with module B of Directive 2014/90/EU on Marine Equipment		

Manufacturer	Name	ANAF FIRE PROTECTION S.P.A.
	Address	Via del Commercio 4 IT - 27020 Torre d'Isola (Pavia) ITALY

Brand Applicant	Name	LALIZAS HELLAS
	Address	3 Gounari, 18531 Piraeus GREECE

Concerned Equipment: Portable Fire Extinguishers (Powder Stored Pressure)

Type: Lalizas 40069X (X is substituted by a number depending available languages on the label)

Technical documents : design ref. 32.890F.F000.00/cert.ref.15/IT/3595

Capacities: 9 kg

Fire Rating : 43A 233B C

Set pressure: max. 15 bar (+60°C)

Test pressure: 22 bar

Service temperature range: min. -30°C / max. +60°C

The manufacturer is allowed to affix the marine CE mark  (followed by the n° and the year of manufacturing) to approved equipment in the conditions described in article 10 of the Directive , only if the requirements stated in module D are fully complied with.

The approval is valid until 01/02/2020

APRAGAZ, acting within the scope of its notification for the above mentioned Directive, certifies that the types of equipment defined here above are conform to the requirements of the EN 3.7 in force and to the Marine Equipment Directive 2014/90/EU (as amended), on base of the documentation and samples supplied for review and approbation.

Date : **05/11/2018**

Name : **Ch. Leplat**

Position **General Manager**

Notified body identification number :

0029

Signature

Notified body stamp :

APRAGAZ
Belgium
Inspecting
Authority

Notified body reference :

P17676/000